

**TABLE 6**  
 Summary of Devices Analytical Results  
 Massachusetts Natural Fertilizer and Otter Farm  
 Westminster, Massachusetts  
 Last Updated: 09/22/2022 (JLL)



Parameter	Sample Date	Location Type	Lab Sample ID	Regulated PFAS Compounds							Non-Regulated PFAS Compounds						
				PFHpA	PFHxS	PFOA	PFNA	PFOS	PFDA	PFAS6	N-EtFOSAA	PFBS	PFDoA	PFHxA	PFTA	PFTTrDA	PFUnA
<b>Sample Location/ID</b>				MassDEP MCP Method 1 GW-1 Criteria 20							NS NS NS NS NS NS NS						
PurePro #1	9/2/22	Device	209080	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
PurePro #1 FB	9/2/22	Device	209081	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
PurePro #2	9/2/22	Device	209082	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
PurePro #2 FB	9/2/22	Device	209083	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #1 S/N 220402246	9/2/22	Device	209074	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #1 S/N 220402246 FB	9/2/22	Device	209075	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #2 S/N 220419571	9/2/22	Device	209076	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #2 S/N 220419571 FB	9/2/22	Device	209077	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #3 S/N 220402238	9/2/22	Device	209078	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00
Viqua #3 S/N 220402238 FB	9/2/22	Device	209079	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	ND	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00	<2.00

MassDEP MCP - Massachusetts Department of Environmental Protection Massachusetts Contingency Plan. Effective 04/25/2014 and updates

NS - No Standard

<xx indicates compound was not reported above laboratory limits, Reporting Limit (RL) provided.

Results presented in nanograms per liter (ng/L)

PFAS - Per- and Polyfluoroalkyl Substances

Only PFAS with results above RL are shown above